



- A BALL VALVE
- B TEST COCK
- C Y-TYPE STRAINER (OPTIONAL)

**NOTE:**

1. BACKFLOW PREVENTER INSTALLATION MAXIMUM OF 10' DOWNSTREAM OF METER.
2. BACKFLOW PREVENTER INSTALLED, OWNED & MAINTAINED BY CUSTOMER.
3. O.U.C. CROSS-CONNECTION CONTROL DEPARTMENT 407-434-2535.



ORLANDO UTILITIES COMMISSION  
 WATER BUSINESS UNIT  
 3800 Gardenia Orlando, FL 32839

ENG.: W.E.	DATE: 03-30-09
DRAWN: WETS	MAP SEC. N/A
W.R. No. N/A	SCALE: N.T.S.
ACAD No.: N/A	FILE: RPZ-SMALL.DWG

**REDUCED PRESSURE ZONE**